


Area Type Averages

Building type:Warehouse. Building size:250K to less than 500K. Shifts:3

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied						
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav		
Warehouse	W	10	234	125.12	0.00	0.00	0.00	125.12	60.21	0.00	0.00	0.00	60.21	51.88%	
Building Average		2340	125.12				0.00	125.12	60.21				0.00	60.21	51.88%



Hours per Week for each Area Type

Data Logger Detail Building type:Warehouse. Building size:250K to less than 500K. Shifts:3

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
23882	Warehouse	W	998.97	998.97	0.00	0.00	0.00	8/06/05 9:03 AM	9/17/05 12:00 AM	751.47	0.00	0.00	0.00	751.47	196.47	0.00	0.00	0.00	196.47
24029	Warehouse	W	999.15	999.15	0.00	0.00	0.00	8/06/05 8:52 AM	9/17/05 12:00 AM	733.73	0.00	0.00	0.00	733.73	277.22	0.00	0.00	0.00	277.22
23855	Warehouse	W	998.82	998.82	0.00	0.00	0.00	8/06/05 9:12 AM	9/17/05 12:00 AM	729.13	0.00	0.00	0.00	729.13	274.77	0.00	0.00	0.00	274.77
23966	Warehouse	W	999.38	999.38	0.00	0.00	0.00	8/06/05 8:38 AM	9/17/05 12:00 AM	757.90	0.00	0.00	0.00	757.90	299.63	0.00	0.00	0.00	299.63
23846	Warehouse	W	998.67	998.67	0.00	0.00	0.00	8/06/05 9:21 AM	9/17/05 12:00 AM	751.22	0.00	0.00	0.00	751.22	202.87	0.00	0.00	0.00	202.87
24263	Warehouse	W	1000.27	1000.27	0.00	0.00	0.00	8/06/05 7:45 AM	9/17/05 12:00 AM	738.80	0.00	0.00	0.00	738.80	500.12	0.00	0.00	0.00	500.12
23853	Warehouse	W	1000.10	1000.10	0.00	0.00	0.00	8/06/05 7:55 AM	9/17/05 12:00 AM	754.08	0.00	0.00	0.00	754.08	463.10	0.00	0.00	0.00	463.10
24026	Warehouse	W	1000.00	1000.00	0.00	0.00	0.00	8/06/05 8:01 AM	9/17/05 12:00 AM	743.00	0.00	0.00	0.00	743.00	522.53	0.00	0.00	0.00	522.53
23993	Warehouse	W	1000.18	1000.18	0.00	0.00	0.00	8/06/05 7:50 AM	9/17/05 12:00 AM	749.98	0.00	0.00	0.00	749.98	430.05	0.00	0.00	0.00	430.05
23994	Warehouse	W	839.73	839.73	0.00	0.00	0.00	8/06/05 7:37 AM	9/10/05 7:20 AM	617.35	0.00	0.00	0.00	617.35	349.47	0.00	0.00	0.00	349.47

Normalized Data Logger Detail Building type:Warehouse. Building size:250K to less than 500K. Shifts:3

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
23882	Warehouse	W	234	126.38	0.00	0.00	0.00	126.38	33.04	0.00	0.00	0.00	33.04	73.86%
24029	Warehouse	W	234	123.37	0.00	0.00	0.00	123.37	46.61	0.00	0.00	0.00	46.61	62.22%
23855	Warehouse	W	234	122.64	0.00	0.00	0.00	122.64	46.22	0.00	0.00	0.00	46.22	62.31%
23966	Warehouse	W	234	127.41	0.00	0.00	0.00	127.41	50.37	0.00	0.00	0.00	50.37	60.47%
23846	Warehouse	W	234	126.37	0.00	0.00	0.00	126.37	34.13	0.00	0.00	0.00	34.13	72.99%
24263	Warehouse	W	234	124.09	0.00	0.00	0.00	124.09	84.00	0.00	0.00	0.00	84.00	32.31%
23853	Warehouse	W	234	126.67	0.00	0.00	0.00	126.67	77.79	0.00	0.00	0.00	77.79	38.59%
24026	Warehouse	W	234	124.82	0.00	0.00	0.00	124.82	87.79	0.00	0.00	0.00	87.79	29.67%
23993	Warehouse	W	234	125.97	0.00	0.00	0.00	125.97	72.24	0.00	0.00	0.00	72.24	42.65%
23994	Warehouse	W	234	123.51	0.00	0.00	0.00	123.51	69.92	0.00	0.00	0.00	69.92	43.39%

Building Summary Totals Building type:Warehouse. Building size:250K to less than 500K. Shifts:3

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	
Warehouse	W	10	2340	293	0	0	293	141	0	0	0	141	
Building Totals			2340	293		0	293	141			0	141	